

## State Water Resources Control Board

June 12, 2018

(Via email and Certified Mail)  
**CERTIFIED MAIL**  
**NO. 7017 2680 0000 6195 8954**

Mr. Mark Grushayev  
Wastewater Treatment Manager  
Sewerage Agency of Southern Marin  
450 Sycamore Avenue  
Mill Valley, California 94941  
[mgrushayev@cityofmillvalley.org](mailto:mgrushayev@cityofmillvalley.org)

**SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEM  
LOCATED AT SEWERAGE AGENCY OF SOUTHERN MARIN, 434 SEMINARY  
DRIVE, MILL VALLEY**

Dear Mr. Grushayev:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the UST at your facility on May 25, 2018, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	<b>Failure to Maintain Monitoring or Testing Records</b> – Three years of manual inventory reconciliation and tank integrity testing records were not available at the time of inspection.	Diesel	May 25, 2018	Ongoing	H&SC 25293; 23 CCR 2712(b)
2	<b>Failure to Maintain Tank Information</b> – In CERS, the recordkeeping section denotes the equipment maintenance and calibration records are not being kept.	Diesel	May 25, 2018	Ongoing	23 CCR 2711(a)

No.	Violation	Tank	Start Date	Stop Date	Regulation
3	<b>Failure to Maintain Plot Plan/Site Map</b> – An approved plot plan/site map indicating the location of the supply and return product piping for the emergency generator tank system was not available in CERS or onsite at the time of the inspection.	Diesel	May 25, 2018	Ongoing	23 CCR 2711(a)(8)

**You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and Marin County Department of Public Works, Waste Management Division within sixty (60) days from the date of this letter. Have your Designated Operator make specific notations in the next monthly designated operator report indicating the ongoing violations have been corrected. The monthly designated operator report and any associated photos must be submitted as proof of compliance.**

Please send all compliance documentation to the following:

**State Water Board**

Mr. Will Speth  
UST Enforcement Unit  
Office of Enforcement  
State Water Resources Control Board  
801 K Street, Suite 2300  
Sacramento, California 95814  
[will.speth@waterboards.ca.gov](mailto:will.speth@waterboards.ca.gov)

**Local CUPA**

Ms. Julia Barnes, Supervisor  
Waste Management Division  
Marin County Department of Public Works  
1600 Los Gatos Drive, Suite 210  
San Rafael, California 94903  
[jbarnes@marincounty.org](mailto:jbarnes@marincounty.org)

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me at (916) 341-5551, or by email at [amantha.henkel@waterboards.ca.gov](mailto:amantha.henkel@waterboards.ca.gov).

Sincerely,



Amantha Henkel  
Senior Environmental Scientist  
UST Enforcement Unit  
**Office of Enforcement**

cc: See next page.

cc: *(via email only)*

Ms. Julia Barnes  
Supervising Hazardous Material Specialist  
Marin County Department of Public Works  
[JBarnes@marincounty.org](mailto:JBarnes@marincounty.org)

Ms. Christie Coleman  
Hazardous Material Specialist  
Marin County Department of Public Works  
[CColeman@marincounty.org](mailto:CColeman@marincounty.org)

Mr. Mark Wilson  
Maintenance Supervisor  
Sewerage Agency of Southern Marin  
[mwilson@cityofmillvalley.org](mailto:mwilson@cityofmillvalley.org)

Mr. Chris Monti  
Chief Treatment Plant Operator  
Sewerage Agency of Southern Marin  
[cmonti@cityofmillvalley.org](mailto:cmonti@cityofmillvalley.org)